



#### NOTES:

1. MINIMUM CURB LONGITUDINAL SLOPE DESIGN STANDARDS SHOW GUTTER FLOW AS .004 FT. PER FT.
2. LIMITS OF SLOPE, CROWN LINE TO OUTSIDE GUTTER, MIN. = 1%, MAX. = 3.8%.
3. CROWN LINE ELEVATION TO BE SHOWN ON THE PLANS.
4. DESIGN SHALL CONFORM TO THESE REQUIREMENTS EXCEPT AS OTHERWISE APPROVED BY THE AGENCY ENGINEER.
5. ALL FACILITIES; CURB, GUTTER, SIDEWALK, AC DIKE, AND EDGE OF PAVEMENT SHALL BE EQUIDISTANT TO THE RIGHT OF WAY LINE.

TITLE:

## KNUCKLE

DRAWN BY:

LOUIE C. GUEVARA

SCALE:

NONE

APPROVED:

*[Signature]*

REVIEWED BY:

DAVID RUBCIC

REVISED:

APRIL, 2013

7-16-13

DATE

STANDARD PLAN

A-2

CITY OF HOLLISTER  
ENGINEERING DEPARTMENT

CITY ENGINEER: RUDI GOLNIK LIC. NO. 39570 EXP. DATE: 12-31-2013

SHEET 1 OF 1